

January 31, 2020

Mr. Erik Waite
Pacific Seismic Products, Inc.
233 East Avenue H8
Lancaster, CA 93535

RE: Earthquake Sensitive Automatic Gas Shutoff Valves (ESV) Certification

Dear Mr. Waite:

The Division of the State Architect (DSA) received your application of certification for Earthquake Sensitive Automatic Gas Shutoff Valves (ESV) under ASCE/ANSI/SEI 25-16. Starting January 1, 2020, the newly issued DSA number will need to be marked on each ESV. This new number is designed to identify the year of compliance with the 2019 California Plumbing Code when the new testing standard (ANSI/ASCE/SEI 25-16) was required. The submitted test reports number SA5723-19970501, and dated 06/04/19 have been verified by DSA and is contingent upon the following:

1. The CA-DSA label shall appear on the valve's markings and the container in compliance with Section 1378, Subchapter 6, Title 21, California Code of Regulations (CCR) labeling requirements. The valves and container shall be marked with the following DSA number.

Product numbers: 300, 301, 302, 303 with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-S03**

Product numbers: 310, 311, 312, 313 with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-S04**

Product numbers: 314, 315, 316, 318 with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-S05**

Product numbers: 314F, 315F, 318F with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-S06**

Product numbers: 316F, 317F, 319F with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-S07**

Product numbers: ES-510 with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-E01**

Product numbers: 400 with and without the prefix H, VT, VB.
DSA label assigned: **DSA 19-E02**

2. All ESV's are subject to independent third party quality control inspections conducted as required by Section 1382(a), Title 21, CCR. Inspections may be made a minimum of four times a calendar year

by a DSA certified Inspection Service Agency as required by Section 1382(e) and copies of the verified inspection reports are to be sent to DSA within 30 days of date of inspection as required by Section 1382 (f) Title 21, CCR.

3. Any changes in or to the certified valve or manufacturing procedures require a new certification unless DSA has granted a modification to the certification per Section 1374.

Sincerely,



Tav Commins

Senior Mechanical Engineer

Tav.Commins@dgs.ca.gov

Phone: 916-443-9841