

August 29, 2016

Mr. Erik Waite  
Pacific Seismic Products, Inc.  
233 East Avenue H8  
Lancaster, CA 93535

Subject: Earthquake Sensitive Automatic Gas Shutoff Valves (ESV) Modification  
Product name: Pacific Seismic Earthquake Actuated Electric Switch Assembly  
Product numbers: Model ES 510  
DSA label assigned: **DSA 16-E01**  
Lab test done by: Underwriters Laboratories, Inc.  
Lab test number: SA5723-19911113, Dated 1/14/14  
Current standard: ANSI/ASCE/SEI 25-06

Dear Mr. Waite:

The Division of the State Architect (DSA) received your Letter of Intent on July 20, 2016 for modification of the certification of the Earthquake Sensitive Actuated Electric Switch (ES) for Gas Shutoff Valves. Starting January 1, 2017, Pacific Seismic Products will need to have this newly issued label assignment marked on each ES. The UL reports have been verified by DSA for the seismic and ruggedness of the ES per ANSI/ASCE/SEI 25-06 and the certification is contingent upon the following:

1. The CA-DSA label shall appear on the ES markings and the container in compliance with Section 1378, Subchapter 5, Title 21, California Code of Regulations (CCR) labeling requirements.
2. Verified inspection services shall notify DSA in writing within 30 days of any changes in company ownership, company address, inspection forms, procedures or any other changes as noted in Section 1382 (g) Title 21, CCR.
3. Independent third party quality control inspections shall be conducted as required by Section 1382(a), Title 21, CCR. Frequency of inspection shall be per ANSI/ASCE/SEI 25-2006, Section 3. Copies of the verified inspection reports are to be sent to DSA within 30 days of date of inspection as required by Section 1382 (f) Title 21, CCR.
4. Any changes in or to the certified valve or manufacturing procedures (standards/code) require a new certification per Section 1374, Certification Limitation, Title 21, CCR.

Sincerely,



**Lydia Barrón, LEED® AP**  
Architectural Associate / DSA High Performance Section (HPS)  
[Lydia.Barron@dgs.ca.gov](mailto:Lydia.Barron@dgs.ca.gov)  
Phone: 916-327-0535